



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA192948

Certificate Holder: Pink River Pty Ltd
675 Macarthur Ave Central
Pinkenba QLD 4008
Australia

Class Description: Non-Prescribed
Product Description: Surge Protection Device (Type 1+2)
Trade Name: OBO BETTERMANN
Model No.: MCF 100-3+NPE+FS
Markings: Uc (50/60Hz) L-N: 255Vac; Iimp L-N: 25kA;
In L-N: 35kA; Up L-N: ≤1.5kV
Uc (50/60Hz) N-PE: 255Vac; Iimp N-PE: 100kA;
In N-PE: 100kA; Up N-PE: ≤1.5kV;
IL: 125A; T1 T2
Standard: IEC 61643-11 Ed 1.0
Conditions: Nil

Certification Mark: RCM and SAA192948

Date First Registered: 12 December 2019
Date of Expiry: 12 December 2024

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 12-12-19 192948/1

www.jas-anz.org/register